



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-51, **Version:** 2

Appeal of Sheila Moore for Capital Siding Windows and Construction, on behalf of Robert and Mary Kuhl, to an Egress Window Non-Compliance Determination at 1804 HIGHLAND PARKWAY.

Nothing indicated.

July 21, 2011

Yes, 5 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Sheila Moore for Capital Siding Windows and Construction, on behalf of Robert and Mary Kuhl, to an Egress Window Non-Compliance Determination at 1804 HIGHLAND PARKWAY, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends tha the City Council grant a 5-inch variance on the openable height of two (2) double-hung replacement egress bedroom windows measuring 19.93 inches high by 26.375 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.