



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 11-269, **Version:** 2

Appeal of James Baker to a Fire Certificate of Occupancy Correction Order at 369 LAUREL AVENUE.

Windows in garden level; see attached.

June 15, 2011

WHEREAS, in the matter of the Appeal of James Baker to a Fire Certificate of Occupancy Correction Order at 369 LAUREL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the egress windows in the garden level bedrooms, and the appellant must install two-steps (7 inches in depth by 11 inches high) the full width of the windows to address the sill height issue; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.