



Legislation Text

File #: RLH FOW 11-100, **Version:** 2

Appeal of Tia Yang and Lee Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 929 WILSON AVENUE.

Double-hung window 1st floor bedroom openable 17.5 inches Ht. X 31.5 Width and Double-hung window 2nd floor bedroom openable 21" Ht. X 27" Width.

July 1, 2011

Yes, 7 inches in the egress opening height of the 1st floor bedroom and 3 inches in the height of the 2nd floor bedroom.

No hearing necessary.

WHEREAS, in the matter of Tia Yang and Lee Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 929 Wilson Avenue; and

WHEREAS, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6.5-inch variance on the openable height of the egress window in the first floor bedroom and grant a 3-inch variance on the openable height of the egress window in the second floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.