



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-126, **Version:** 2

Appeal of Robert E. Gotch to Revocation of Fire Certificate of Occupancy and Order to Vacate at 1009 THOMAS AVENUE (appealing windows only).

Window size

July 25, 2011

Yes, 2 bedrooms on 1st floor and 2nd floor front bedroom: 3 inches in egress opening height Hearing for 2nd floor rear room.

WHEREAS, in the matter of the Appeal of Robert E. Gotch to Revocation of Fire Certificate of Occupancy and Order to Vacate at 1009 THOMAS AVENUE (appealing windows only), the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant 90 days extension for the 2nd floor, rear room (top of the stairway); grant a 3-inch variance on the openable height of the egress windows in the first floor, 2 bedrooms; and grant a 7-inch variance on the openable height of the egress window in the 2nd floor, front room; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.