



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-125, **Version:** 2

Appeal of Sandra Youngdahl to an Egress Window Non-Compliance Determination at 2086 ELEANOR AVENUE.

See attachment

July 29, 2011

Yes, 4 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Sandra Youngdahl to an Egress Window Non-Compliance Determination at 2086 ELEANOR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5-inch variance on the openable height of the first floor north and south bedroom windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.