



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-57, **Version:** 3

---

Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE.

Request to replace conforming window w/non conf. replacement.

July 19, 2011

Yes, 3 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable width of one double-hung egress bedroom window measuring 28 inches openable height and 17.5 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.