



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-132, **Version:** 2

Appeal of Jose Gutierrez to a Fire Certificate of Occupancy Inspection Correction Notice at 1726 SIMS AVENUE.

(Only egress windows)

August 1, 2011

Yes, 5 inches in egress opening height of all bedrooms.

No hearing necessary.

WHEREAS, in the matter of the Appeal of Jose Gutierrez to a Fire Certificate of Occupancy Inspection Correction Notice at 1726 SIMS AVENUE; and

WHEREAS, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the windows in all bedrooms measuring 19 inches openable high by 37 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.