



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 11-312, **Version:** 2

Appeal of Mark Grondahl to a Fire Certificate of Occupancy Inspection Correction Notice at 1654 MCAFEE STREET.

(Items 2, 10, 12 - See attached letter)

August 4, 2011

Item 10. 42 inches high by 20 inches wide (in compliance)

Hearing on Items 2 and 12.

WHEREAS, in the matter of the Appeal of Mark Grondahl to a Fire Certificate of Occupancy Inspection Correction Notice at 1654 McAfee Street; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal for Item 2 (clearance around electrical panel); and deny the appeal for Item 12 (extension cords); Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.