



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-62, **Version:** 2

Appeal of Ramsey County Department of Public Health, on behalf of Joshua Capistrant, to an Egress Window Non-Compliance Determination 220 FAIRVIEW AVENUE NORTH.

See attached form

August 16, 2011

Yes, 2 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Ramsey County Department of Public Health, on behalf of Joshua Capistrant, to an Egress Window Non-Compliance Determination 220 FAIRVIEW AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the three double hung replacement egress bedroom windows measuring 22 high by 25.3 wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.