



Legislation Text

File #: RLH FOW 11-131, **Version:** 2

Appeal of Janet Contursi to a Fire Certificate of Occupancy Inspection Correction Notice at 2041 MONTREAL AVENUE.

Please see #4 on Page 2. The windows are 18.5 H X 23.5 W. This is a condominium association. I own the unit, but am renting it now. Everyone else in the building owns their units, so this correction only applies to me, but I cannot change windows or any exterior fixtures because it's a condo & everything must be uniform in appearance. Thank you.

August 11, 2011

Yes, 6 inches in the egress opening height of the north and south facing sleeping rooms.

No hearing necessary.

WHEREAS, in the matter of the Appeal of Janet Contursi to a Fire Certificate of Occupancy Inspection Correction Notice at 2041 MONTREAL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant 6 inch variance in the height of the egress window openings in the north and south bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.