



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-78, **Version:** 2

---

Appeal of Mai Vang to an Egress Window Non-Compliance Determination at 1491 DIETER STREET.

Egress windows

August 22, 2011

Yes, 7 and 6 inches in egress opening height of windows, and 2 inch variance on sill height requirement. No hearing necessary.

WHEREAS, in the matter of the appeal of Mai Vang to an Egress Window Non-Compliance Determination at 1491 DIETER STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant 7 and 6-inches variances for three slider replacement bedroom windows measuring 17 high by 27 wide and 18 high by 33 wide and grant a 2-inch variance on the sill height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.