



## Legislation Text

---

**File #:** RLH FOW 11-147, **Version:** 2

---

Appeal of Michael and Marcia Conroy to a Fire Certificate of Occupancy Inspection Correction Notice at 881 MCKNIGHT ROAD NORTH.

22" openable ht x 33.25" = 10.6' net opening is more than sufficient space. All windows are operating.

August 17, 2011

Yes, 2 inch variance in egress opening height.

WHEREAS, in the matter of the Appeal of Michael and Marcia Conroy to a Fire Certificate of Occupancy Inspection Correction Notice at 881 MCKNIGHT ROAD NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.