



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-67, **Version:** 2

---

Appeal of Sandau Construction Co., Inc. to an Egress Window Non-Compliance Determination at 1937 JEFFERSON AVENUE.

replacement egress windows - 22 h by 29 w

September 1, 2011

Yes, 2 inch variance in egress opening height. No hearing necessary.

WHEREAS, in the matter of Sandau Construction Co., Inc. to an Egress Window Non-Compliance Determination at 1937 JEFFERSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of six double-hung replacement egress bedroom windows measuring 22 inches high by 29 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.