



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-77, **Version:** 2

Appeal of Saint Paul Ramsey County Department of Public Health, on behalf of True Hang and Suenie Yang, to an Egress Window Non-Compliance Determination at 945 EDMUND AVENUE.

(4 windows)

September 23, 2011

Yes, 2 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 945 EDMUND AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of four double-hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.