



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-87, **Version:** 2

Appeal of Renewal by Andersen to two Egress Window Non-Compliance Determinations at 2053 IOWA AVENUE EAST.

We are appealing 3 replacement windows that will not comply w/egress policy. Openable height will be short by 5". Width & glazed area criteria is met/exceeded. Specific sizes attached. Please approve.

October 3, 2011 (both)

WHEREAS, in the matter of the Appeal of Renewal by Andersen to two Egress Window Non-Compliance Determinations at 2053 IOWA AVENUE EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high by 36 inches wide, and grant a 5-inch variance on the openable height of one double hung replacement egress bedroom window measuring 19 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.