



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-194, **Version:** 2

Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET.

Only egress windows - Height variance of 1", 23" height where 24" is required

October 10, 2011

WHEREAS, in the matter of Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress window in the upper unit northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.