



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-181, **Version:** 2

Appeal of Gretchen Iwen to a Fire Certificate of Occupancy Inspection Correction Notice at 1899 BEECHWOOD AVENUE.

Double hung windows are 1.5/1 inch short of what they are suppose to be.

September 16, 2011

Yes, 2 inches in egress window opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Gretchen Iwen to a Fire Certificate of Occupancy Inspection Correction Notice at 1899 BEECHWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.5-inch variance on the openable height of the egress window in the north bedroom and grant a 1-inch variance on the openable height of the egress window in the south bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.