



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-221, **Version:** 2

---

Appeal of Daniel Schmidt, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 240 WYOMING STREET EAST.

(2 egress windows)

October 20, 2011

RC Public Health.

Yes, 5 inch variance in egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 240 WYOMING STREET EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung wood acraft replacement egress bedroom windows measuring 19-3/4 inches high by 22.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.