



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-89, **Version:** 2

---

Appeal of Pella Windows, on behalf of Jennifer Conroy, to a Fire Certificate of Occupancy Correction Notice at 2175 JEFFERSON AVENUE.

Pella is asking to replace all windows in residence with current style of double hung windows.

October 6, 2011

Yes, 3 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Pella Windows, on behalf of Jennifer Conroy, to a Fire Certificate of Occupancy Correction Notice at 2175 JEFFERSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 21 inches high by 22.9 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.