



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-198, **Version:** 2

Appeal of Relando Aguilar to a Fire Certificate of Occupancy Correction Notice at 833 YORK AVENUE.

None listed

September 26, 2011

Yes, 4 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Relando Aguilar to a Fire Certificate of Occupancy Correction Notice at 833 YORK AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5 inch variance on the openable height of the egress window in the south bedroom of Unit 2; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.