



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-93, **Version:** 2

---

Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE.

Egress window non-compliance

August 17, 2011

Yes, 2 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of five double hung replacement egress bedroom windows measuring 42 inches high by 18 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.