



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-212, **Version:** 2

Appeal of Kimberly A. Jones to a Fire Certificate of Occupancy Correction Notice at 659 SURREY AVENUE.

Variance of second floor egress windows.

October 13, 2011

Yes, 4 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Kimberly A. Jones to a Fire Certificate of Occupancy Correction Notice at 659 SURREY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in all second floor bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.