



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-102, **Version:** 2

Appeal of Ramsey County Department of Public Health (Daniel Schmidt), on behalf of Jeff Manders, to an Egress Window Non-Compliance Determination at 1808 HYACINTH AVENUE EAST.

[Enter the Reason for the Appeal]

October 25, 2011

RC Public Health

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Ramsey County Department of Public Health (Daniel Schmidt) to an Egress Window Non-Compliance Determination at 1808 HYACINTH AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.