



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-103, **Version:** 2

---

Appeal of Richard Kedrowski to an Egress Window Non-Compliance Determination at 1190 MAGNOLIA AVENUE EAST.

Egress window non-compliance

October 25, 2011

DD

No hearing necessary.

Yes, 1 inch in egress opening height.

WHEREAS, in the matter of the Appeal of Richard Kedrowski to an Egress Window Non-Compliance Determination at 1190 MAGNOLIA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of two slider replacement egress bedroom windows measuring 23.6 inches high by 20.65 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.