



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-227, **Version:** 2

Appeal of Khamphiou Vang to a Fire Certificate of Occupancy Correction Notice at 728 ROSE AVENUE EAST.

Windows

September 20, 2011

Mike Cassidy

No hearing necessary. Note, variance does not pertain to first floor window repairs.

Yes: 2nd floor east and north bedrooms - 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Khamphiou Vang to a Fire Certificate of Occupancy Correction Notice at 728 ROSE AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in the 2nd floor east and north bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.