



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-210, **Version:** 2

Appeal of Paoze Her and Song Lor to a Fire Certificate of Occupancy Correction Notice at 1631 BIRMINGHAM STREET.

#2, 3, 4, 5 - These windows are the original windows from when the house was built. We did not modify or replace any windows in this house or alter any window ?? in the home.

October 4, 2011

Yes, bedroom NW side - 8 inches minimum sill height, if 2 standard size steps installed for the length of the window. Hearing necessary on the balance of the appeal.

WHEREAS, in the matter of the Appeal of Paoze Her and Song Lor to a Fire Certificate of Occupancy Correction Notice at 1631 BIRMINGHAM STREET the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a variance on the minimum sill height of the egress window provided 2 standard size steps are installed; and Deny the appeal on the egress bedroom window egress dimensions and grant an extension for 90 days to bring the windows into compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.