



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 11-120, **Version:** 2

---

Appeal of Ha T. Duong to an Egress Window Non-Compliance Determination at 1523 and 1525 REANEY AVENUE.

The property was built in 1973.

October 20, 2011

None listed.

There is no inspector name on the determination.

Yes, 4 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Ha T. Duong to an Egress Window Non-Compliance Determination at 1523 and 1525 REANEY AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of four double hung replacement egress bedroom windows measuring 20 inches high by 30 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.