



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 11-241, **Version:** 2

Appeal of Todd Funke to a Fire Certificate of Occupancy Correction Notice at 144 LEXINGTON PARKWAY NORTH.

#6 - Window size for escape windows in sleeping room.

October 27, 2011

Rick Gavin

No hearing necessary.

Yes, 5 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Todd Funke to a Fire Certificate of Occupancy Correction Notice at 1865 OLD HUDSON ROAD, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the east, south, southwest and northwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.