



Legislation Text

File #: RLH WP 11-114, **Version:** 2

Appeal of Budget Exterior, on behalf of Ronald Burth and Shannon Burth McDonald, to two Egress Window Non-Compliance Determinations at 1077 ENGLEWOOD AVENUE.

Windows

November 3, 2011 for both

J. Hoffman

Yes, a 5 inch variances in egress opeing height for 4 double hung windows with egress opening dimensions of 5 inches in egress opening dimensions of 21"W and 19"H.

Hearing required for 2 double hung windows with egress opening dimensions of 15"H and 17"W.

WHEREAS, in the matter of the Appeal of Budget Exterior, on behalf of Ronald Burth and Shannon Burth McDonald, to two Egress Window Non-Compliance Determinations at 1077 ENGLEWOOD AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of four double hung replacement egress bedroom windows measuring 19-1/6 inches high by 21-3/4 inches wide, and deny the appeal on two double hung replacement egress bedroom windows measuring 15-1/16 inches high by 17-3/4 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.