



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-252, **Version:** 2

---

Appeal of Judith Day to a Fire Certificate of Occupancy Inspection Correction Notice at 934 ASHLAND AVENUE.

Please see attached list from inspector. I have removed the bars from the window and am also giving the tenant (2) small step ladders to place beneath the windows in case tenant needs to leave apt. by window. I have had these windows for several years and have not any problems with tenants or inspector. They have two doors to leave apt.

November 16, 2011

Rick Gavin

No hearing necessary if only item under appeal is the window dimensions, and the other item has been addressed by the owner.

Yes, unit 5 north bedroom, a 4 inch variance in egress opening height.

WHEREAS, in the matter of the Appeal of Judith Day to a Fire Certificate of Occupancy Inspection Correction Notice at 934 ASHLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City council grant a 4-inch variance on the openable height of the egress windows in the north bedroom of Unit 5; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.