



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-126, **Version:** 2

Appeal of Chamee Her to an Egress Window Non-Compliance Determination at 1725 LOUISE AVENUE.

Windows

December 1, 2011

N/A

Hearing necessary. (Variance request is for 9 inches; e.g. opening height 15 inches)

WHEREAS, in the matter of the \Appeal of Chamee Her to an Egress Window Non-Compliance Determination at 1725 LOUISE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal on the window measuring 15 inches high by 29 inches wide and grant a 90-day extension to come into compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.