



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 11-255, **Version:** 2

---

Appeal of Tab Properties, on behalf of Jenna Anderson, to a Fire Certificate of Occupancy Correction Notice at 1199 ALBEMARLE STREET.

See attached

October 13, 2011

Leanna Shaff

No hearing necessary.

Yes, 3 inches in egress opening height in both bedrooms.

WHEREAS, in the matter of the Appeal of Tab Properties, on behalf of Jenna Anderson, to a Fire Certificate of Occupancy Correction Notice at 1199 ALBEMARLE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in both bedrooms of the apartment; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.