



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-10, **Version:** 2

Appeal of Luke Hannigan to a Fire Certificate of Occupancy Correction Notice at 1895-1897 MONTANA AVENUE.

None listed

December 1, 2011

James Thomas

No hearing necessary.

Yes, 4 inches egress opening height - both units.

WHEREAS, in the matter of the Appeal of Luke Hannigan to a Fire Certificate of Occupancy Correction Notice at 1895-1897 MONTANA AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant 4-inch variance on the openable height of the egress windows in both bedrooms at 1895 and 1897; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.