



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-12, **Version:** 2

Appeal of Vatou Her to a Fire Certificate of Occupancy Correction Notice at 614 ROSE AVENUE.

Two window size - 21 in. height x 26.5 in. wide, 19 in. height x 25.5 in. width

December 14, 2011

Mike Cassidy

No hearing necessary.

Her was called and told that the appeal has been granted on the windows. -rrn

Yes, 3 inches egress opening height - first floor and 5 inches egress opening height - second floor.

WHEREAS, in the matter of the Appeal of Vatou Her to a Fire Certificate of Occupancy Correction Notice at 614 ROSE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in the first floor bedroom and a 5-inch variance on the openable height of the egress windows in the 2nd floor northeast and northwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.