



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-9, **Version:** 2

---

Appeal of Pema Tso to a Fire Certificate of Occupancy Correction Notice at 1162 ARUNDEL STREET.

I have a plan to open a day care in my house and fire inspector told us that our bedroom windows are a little bit smaller but our windows condition still quite good so please grant a variance. Thank you so much.

December 8, 2011

James Perucca

No hearing necessary. When appellant is called, please inquire about item #2 on the orders and whether that is under appeal. If so, we'll need dimensions.

Yes, bedrooms 1, 2 and 3 - 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Pema Tso to a Fire Certificate of Occupancy Correction Notice at 1162 ARUNDEL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in bedrooms 1, 2 and 3; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.