



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 12-10, **Version:** 3

Appeal of James Schoffman to a Fire Certificate of Occupancy Correction Notice at 1343 STILLWATER AVENUE.

#1 and 4 of letter

December 7, 2011

James Thomas

Hearing necessary.

AMENDED 2/1/12

WHEREAS, in the matter of the Appeal of James Schoffman to a Fire Certificate of Occupancy Correction Notice at 1343 STILLWATER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension for 90 days to bring the awning windows into compliance; grant the appeal on the sill height issue provided fixed steps are installed full width below the egress windows and grant the appeal on the chimneys, fireplaces and vents; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.