



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 12-10, **Version:** 3

Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE.

(Windows)

January 16, 2012

(none listed)

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide, and grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 26.8 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.