



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-60, **Version:** 2

Appeal of James Nelson to a Fire Inspection Correction Notice at 1148 FIFTH STREET EAST.

See attachment (sleeping room windows)

January 24, 2012

Wayne Spiering

No hearing necessary.

Yes, main and upper floor southeast bedrooms-2 inches egress opening height; and for the north bedroom - 2.5 inches egress opening height and 2 inches egress opening width.

WHEREAS, in the matter of James Nelson to a Fire Inspection Correction Notice at 1148 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in the main floor southeast and upper southeast bedrooms, and grant a 2.5-inch variance on the openable height and a 2-inch variance on the openable width of the egress window in the upper floor north bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.