



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-51, **Version:** 2

Appeal of Denise Hutchins, on behalf of Volunteers of America, MN, to a Fire Certificate of Occupancy Correction Notice at 1436 ASHLAND AVENUE.

[Enter the Reason for the Appeal]

January 17, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Denise Hutchins, on behalf of Volunteers of America, MN, to a Fire Certificate of Occupancy Correction Notice at 1436 ASHLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the first floor, northeast bedroom and a 1-inch variance on the openable height of the first floor southeast bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.