



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-87, **Version:** 2

Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 789 HYACINTH AVENUE EAST.

#5 North and south bedrooms - Request variance on openable height.

February 8, 2012

Mike Cassidy

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 789 HYACINTH AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the north and south bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.