



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-105, **Version:** 2

---

Appeal of John Carrier to a Fire Certificate of Occupancy Approval With Corrections at 1663 and 1665 MCAFEE STREET.

(Only egress windows)

February 17, 2012

James Thomas

No hearing necessary.

Yes, 8 inches egress opening height for all bedroom windows.

WHEREAS, in the matter of the Appeal of John Carrier to a Fire Certificate of Occupancy Approval With Corrections at 1663 and 1665 MCAFEE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress windows in all bedrooms of Units 1663 and 1665; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.