



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-127, **Version:** 2

Appeal of Guy Buonincontro to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1120 BURNS AVENUE.

I have 2 windows that were replaced before I bought the property. They are 1/2" too small to pass. I am asking for an approval.

March 22, 2012

Wayne Spiering

No hearing necessary.

Note - orders for all windows but the lower unit southwest were unnecessary as dimensions were within range.

Yes, upper unit - 2 inches egress opening height. Lower unit northeast and southeast bedrooms - 3 inches egress opening height; southwest - 2 inches egress opening height and 1 inch egress opening width.

WHEREAS, in the matter of the Appeal of Guy Buonincontro to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1120 BURNS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in the upper unit and southwest bedrooms; and grant a 3-inch variance on the openable height of the egress windows in the lower unit northeast and southeast bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.