



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-122, **Version:** 2

Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 1172 SUPORNICK LANE.

Request variance on openable height.

March 27, 2012

James Thomas

No hearing necessary.

Yes, 6 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 1172 SUPORNICK LANE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance in egress window opening height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.