



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-120, **Version:** 2

Appeal of Lori Kustritz, oh behalf of EMK Holding Company, to a Correction Notice - Complaint Inspection at 1191 RICE STREET.

2nd appeal. 1st measurement wasnot accurate (Lisa Martin measured 15 x 24). Leanna S. measured it @ 17 x 25.5.

March 28, 2012

Leanna Shaff

No hearing necessary.

Yes, 7 inches egress opening height.

WHEREAS, in the matter of the Appeal of Lori Kustritz to a Correction Notice - Complaint Inspection at 1191 RICE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance in egress window opening height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.