



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-136, **Version:** 2

---

Appeal of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 1176 SUPORNICK LANE.

Egress Windows

April 4, 2012

James Thomas

No hearing necessary.

Yes - 6-inch variance in height of egress opening

WHEREAS, in the matter of Tony Swanson, Public Housing Agency, to a Fire Certificate of Occupancy Correction Notice at 1176 SUPORNICK LANE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress windows in all bedrooms of Units A and B; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.