



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-121, **Version:** 2

Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 793 IGLEHART AVENUE.

#2 Double Hung Windows - Request variance on openable height.

March 14, 2012

Rick Gavin

No hearing necessary.

Yes, 2 inches egress opening height for listed windows. Also, orders were not necessary for windows of these dimensions.

WHEREAS, in the matter of the Appeal of Tony Swanson, Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Inspection Correction Notice at 793 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance in egress opening height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.