



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FOW 12-118, **Version:** 2

Appeal of Randy McLevish to an Egress Window Non-Compliance Determination at 534 MARSHALL AVENUE.

Opening size changed by Fire Marshall and very close double hung to new requirement size.

March 22, 2012

Rick Gavin

No hearing necessary.

Yes, 3 inches egress opening height. Orders unnecessary for windows of these dimensions.

WHEREAS, in the matter of the Appeal of Randy McLevish to an Egress Window Non-Compliance Determination at 534 MARSHALL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance in the egress opening of the listed windows; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.