



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 12-222, **Version:** 2

Appeal of Admark to a Fire Certificate of Occupancy Inspection Correction Notice at 669 LAUREL AVENUE.

Items 2 and 5 (basement and windows)

February 28, 2012

William Beumer

Hearing on the balance of the appeal.

Yes, 6 inches egress opening height and 0.25 square feet glazed area.

WHEREAS, in the matter of the Appeal of Admark to a Fire Certificate of Occupancy Inspection Correction Notice at 669 LAUREL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the egress bedroom windows in Unit 1; deny the appeal on the electrical panel and grant an extension to November 1, 2012 for compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.