



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-154, **Version:** 2

---

Appeal of Allison Schmitt to a Fire Certificate of Occupancy Correction Notice at 1717 ROSS AVENUE.

Bedroom escape windows smaller than required (height only).

April 6, 2012

James Thomas

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Allison Schmitt to a Fire Certificate of Occupancy Correction Notice at 1717 ROSS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.