



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-169, **Version:** 2

---

Appeal of Jeff Bajek, Venture Bank, to a Fire Certificate of Occupancy Inspection Correction Notice at 1350 SAINT CLAIR AVENUE.

Appealing Item 4 - Approved escape window from each sleeping room. Windows are original to property and are in acceptable condition.

September 29, 2011

Rick Gavin

No hearing necessary.

Yes, 4 inches for all listed windows.

WHEREAS, in the matter of the Appeal of Jeff Bajek, Venture Bank, to a Fire Certificate of Occupancy Inspection Correction Notice at 1350 SAINT CLAIR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress bedroom in the upper unit; and grant a 2.5-inch variance on the openable height of the egress windows in the first floor north and south bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.